

Bath County Health Department P. O. Box 120 Warm Springs, Virginia 24484 (540) 839-7246 Voice (540) 839-2964 Fax

Sewage Disposal System Operation Permit

Health Department ID Number: 108-12-0012

Tax Map No.:

92-36C

GPIN:

Type of Property: Residential

Owner: EDWARDS, Mark

668 Jackson River turnpike Hot Springs, Virginia 24445 Phone: (540) 839-6305

Cell: (540)

Fax: (540)

The Above is Hereby Granted Permission to Operate a/an Conventional Onsite Sewage System at: 668 Jackson River Turnpike Hot Springs, Virginia 24445

Design Capacity for this system is: 450 gallons per day 3 Bedrooms

System serves home at 668 Jackson River Turnpike and the 1 bedroom living quarters in building at the property; total occupancy limited to 6 persons maximum.

This Permit is Issued in Accordance with the Provisions of Title 32.1, Chapter 6 of the Code of Virginia as Amended and

- Section(s) 240 and 340 of Sewage Handling and Disposal Regulations of the Virginia Department of Health
- Sewage Disposal System Construction Permit Dated June 19, 2012.
- Section 60 of the Regulations for Alternative Onsite Sewage Systems of the Virginia Department of Health
- Notable Performance Requirements:

12 VAC 5-610-340. The issuance of an operation permit does not denote or imply any guarantee by the department that the sewage disposal system will function for any specified period of time. It shall be the responsibility of the owner or any subsequent owner to maintain, repair or replace any sewage disposal system that ceases to operate as defined in the operation permit and in 12 VAC 5-610-350.

August 13, 2012

Jason Weakley

Effective Date

Environmental Health Supervisor Approved

Completion Statement

Date

C.H.S. 203 Rev. 4/83

Signature and Title



Bath County Health Department P. O. Box 120 Warm Springs, Virginia 24484 (540) 839-7246 Voice (540) 839-2964 Fax

August 13, 2012

EDWARDS, Mark 668 Jackson River turnpike Hot Springs, Virginia 24445

Subject: Tax Map # and/or GPIN: HDID #: 108-12-0012

Dear EDWARDS, Mark:

The current status of your system installation is as follows: Sewer Line; 4" SCH 40 PVC gravity sewer line from building to septic tank.

Septic Tank; Tank Purpose: Septic Tank; Comments: Septic tank at existing house (668 Jackson River Turnpike); no changes made.

Septic Tank; Tank Purpose: Septic Tank; Volume: 1000 gal; Material: Concrete (pre-cast); Comments: Septic tank for 1BR apt. at building;

Conveyance; Method: Gravity; Line Diameter: 4 in; Material: Sch 40 Plastic; Comments: line from septic tank to pump tank;

Pump; Comments: existing pump used; no changes made;

Conveyance; Method: Pump; Line Diameter: 2 in; Material: Sch 40 Plastic;

Distribution; Method: Distribution Box; Material: Concrete Box;

Trench Dispersal Area; Design Type: Standard; Reserve Area Required: 0%; Header Line Material: Smooth-bore plastic; Size of Pipe: 4 in; Above / Below Grade: Below Grade; Infiltration Type: Trench; Sized for Septic Tank Effluent: Yes; Number of Trenches (Set 1): 7; Length of Trenches (Set 1): 50 ft; Width of Trenches (Set 1): 3 ft; Depth of Trenches (Set 1): 18 in; Trench Center Spacing (Set 1): 9 ft; Aggregate/Media Type (Set 1): Gravel; Aggregate/Media Depth (Set 1): 13 in; Aggregate/Media Size (Set 1): .5-1.5"; Comments: Existing drainfield; originally installed and inspected as 108-93-37;

Last inspected on June 29, 2012

Satisfactory: Yes

Comments: Items in Bold above were installed as part of 108-12-0012; other items were

existing.
Pass: Yes

Followup Required: No

If you have any questions, please contact Bath County Health Department at (540) 839-7246.

Sincerely,

Jason Weakley

Environmental Health Supervisor

C: Local Building Official

