

**Commonwealth of Virginia
Uniform Water Well Completion Report**

Owner Meg Cooper
 Address TURKEY TAFT ROAD
 Phone _____
 Location _____

Tax Map ID 74
 VDH Permit 181-01-038
 WVCB Permit _____
 WVCB ID _____
 County Rockbridge

* Well Data *

General Information

Drilling Method AIR
 Depth to Bedrock 8ft
 Static Water Level _____
 Well Disinfected (Y or N) _____

Date Completed 11-30-04
 Yield 8-10 (GPM)
 Stabilized Water Level _____
 Disinfectant Used _____

Total Depth of Well 265ft
 Length of Test 2 hrs
 Natural Flow (Rate) _____
 Amount Used _____

Casing

From 0 to 153
 Size 6 7/8 Material Steel
 Weight/Schedule 0.188

From _____ to _____
 Size _____ Material _____
 Weight/Schedule _____

From _____ to _____
 Size _____ Material _____
 Weight/Schedule _____

Gravel Pack

From _____ to _____

From _____ to _____

From _____ to _____

Grout

From 0 to 20
 Bore Hole Size 1 1/2 inch
 Type Bentonite
 Method Pump

From _____ to _____
 Bore Hole Size _____
 Type _____
 Method _____

From _____ to _____
 Bore Hole Size _____
 Type _____
 Method _____

Water Zones or Screened Intervals


From 230 to 231
 Mesh Size _____ Diam. _____
 From _____ to _____
 Mesh Size _____ Diam. _____

From _____ to _____
 Mesh Size _____ Diam. _____
 From _____ to _____
 Mesh Size _____ Diam. _____

From _____ to _____
 Mesh Size _____ Diam. _____
 From _____ to _____
 Mesh Size _____ Diam. _____

* Use Data *

Private Well: Domestic Agricultural _____ Industrial _____ Monitoring _____
 Public Well: Community Non Community _____



3404 Aerial Way Drive • Roanoke, VA 24018
 Phone (540) 343-3618 • Fax (540) 342-2054

Gregory Cooper
 6 Wallace Street
 Lexington VA 24450

Environ
 Services
 Certificate

Date Reported: December 14, 2005

Sample Code: 05-5890

Chain of Custody Information

Date Collected: December 13, 2005
 Time Collected: 1000
 Collected By: Client
 Collection Method: Grab
 Sample Description: 525 Turkey Trot Drive
 Lexington, Va.

Date Received: December 13, 2005
 Time Received: 1330
 Sample Type: Drinking Water

Project Name: Homeowner's Analysis

Analytical Notes: Analysis indicates sample meets the standards established by the U.S.E.P.A. for drinking water.

Project Notes: DL= Detection Level

Analytical Data and Quality Assurance Information

Parameter	Result	DL	Method	Date/Time	Analyst
Bacteria	Absent	Present/Absent	ONPG-MUG	12/13/05 1400	JHW
Total Coliform	Absent	Present/Absent	ONPG-MUG	12/13/05 1400	JHW
E. Coli					

Sample Code: 05-5890

Analytical data meet precision and accuracy criteria established by the U.S.E.P.A. for drinking water, waste water, and solid wastes. Exceptions are noted in the analytical notes section of the certificate of analysis. Handling, preservation and collection of samples are performed according to E.P.A. protocol and 40 CFR part 136 and/or 141 and amendments.

Laboratory Certification No: Virginia #00423

Handwritten signature